

PROPOSED REPLACEMENT OF DOORS AND/OR WINDOWS

- REPLACEMENT TO BE SAME SIZE
- FIELD VERIFY REPLACEMENT MEETS EGRESS REQUIREMENTS
- REPLACEMENT TO MEET ENERGY EFFICIENCY REQUIREMENTS (SEE BELOW)

WINDOW/DOOR INSTALLATION

2006 IRC, Chapter 11 Table N1102.1, Zone 3	U-Factor Maximum	U-Factor Spec'd
Fenestration Windows, Doors & Skylights	.65	.65 or better
Glazed Fenestration SHGC Windows, Glazed Doors & Skylights	.40	.40 or better

INSULATION INSTALLATION

2006 IRC, Chapter 11 Table N1102.1, Zone 3	R-Value Minimum
Walls	R-13
Floors	R-19
Ceilings	R-30
Mass Walls	R-5
Basement Walls	NA
Slabs	NA
Crawl Space Walls	R-5 / R-13
Supply and Return Ducts	R-8
Ducts in Floor Trusses	R-6